



Texas Department of State Health Services Laboratory Report

South Texas Laboratory
1301 S. Rangerville Road
Harlingen, TX 78552
(956) 364-8746
CLIA: 45D0503753

Submitter: LAGUNA MADRE WATER DISTRICT (TX0310005)
Noe Cantu
105 PORT RD
Port Isabel, TX 78578

LIMS Report #: 2577935

Date / Time Received:	7/24/2019 2:02 pm	Sample Type:	Special
Received By:	LCASTANEDA	Water Source:	N/A
Date Collected:	7/24/2019	County:	Cameron
Time Collected:	9:10 AM	Submitter Designate:	
Collected By:	Pablo Villarreal Jr	Facility ID:	0310005
Sampler Phone Num:	956 572 0382	Smp Collect Pt Name:	
System Type:	Public (PWS)	Turbidity (NTU):	
Sample Temp (°C):	16.8	Disinfect Resid (mg/L):	1.3
Well Depth (ft):		Disinfect Type:	Chloramine (Total Chlorine)
Sample Condition:	ICED	Facility Name:	Laguna Madre
Sample Site:	6100 Padre Blvd 31	Smp Collect Pt ID:	
Sample #:	SCW1906104 (2664685)	Date Reported:	7/25/2019 10:31 am
Source:	Water		
Billing Comment:	10 - None		
Additional Info:			

Test	Result
Laboratory Chlorine Residual Check	Absent
Colilert Presence - Absence (SM9223)**	Coliforms not found; Escherichia coli not found.
Colilert Test Used	Colilert-18
Date/Time Incubation Started	07/24/2019 02:14:00 PM
Date/Time Incubation Ended	07/25/2019 08:14:00 AM

Note: Water of satisfactory bacteriological quality must be free from coliform organisms. For questions about standards or treatment, call TCEQ at 512-239-4691.

The test results on this report relate only to the sample identified on this report. The test results for analytes noted (*) on this report meet ISO/IEC 17025:2005 requirements. The test results for analytes noted (**) on this report meet TNI (2009 standard) requirements.

Authorized by:

Lab Contact: Deborah Serrato (956) 364-8749

Grace Kubin

Grace Kubin, Ph.D.
Director, Laboratory Services Section

Final

Texas Department of State Health Services Laboratory Report



South Texas Laboratory
1301 S. Rangerville Road
Harlingen, TX 78552
(956) 364-8746
CLIA: 45D0503753

Submitter: LAGUNA MADRE WATER DISTRICT (TX0310005)
Noe Cantu
105 PORT RD
Port Isabel, TX 78578

LIMS Report #: 2577937

Date / Time Received:	7/24/2019 2:02 pm	Sample Type:	Special
Received By:	LCASTANEDA	Water Source:	N/A
Date Collected:	7/24/2019	County:	Cameron
Time Collected:	10:30 AM	Submitter Designate:	
Collected By:	Pablo Villarreal Jr	Facility ID:	0310005
Sampler Phone Num:	956 572 0382	Smp Collect Pt Name:	
System Type:	Public (PWS)	Turbidity (NTU):	
Sample Temp (°C):	18.3	Disinfect Resid (mg/L):	1.0
Well Depth (ft):		Disinfect Type:	Chloramine (Total Chlorine)
Sample Condition:	ICED	Facility Name:	Laguna Madre
Sample Site:	Padre and Shore Dr 32	Smp Collect Pt ID:	
Sample #:	SCW1906106 (2664687)	Date Reported:	7/25/2019 10:31 am
Source:	Water		
Billing Comment:	10 - None		

Additional Info:

Test	Result
Laboratory Chlorine Residual Check	Absent
Colilert Presence - Absence (SM9223)**	Coliforms not found; Escherichia coli not found.
Colilert Test Used	Colilert-18
Date/Time Incubation Started	07/24/2019 02:14:00 PM
Date/Time Incubation Ended	07/25/2019 08:14:00 AM

Note: Water of satisfactory bacteriological quality must be free from coliform organisms. For questions about standards or treatment, call TCEQ at 512-239-4691.

The test results on this report relate only to the sample identified on this report. The test results for analytes noted (*) on this report meet ISO/IEC 17025:2005 requirements. The test results for analytes noted (**) on this report meet TNI (2009 standard) requirements.

Authorized by:

Lab Contact: Deborah Serrato (956) 364-8749

Grace Kubin

Grace Kubin, Ph.D.
Director, Laboratory Services Section

Final

Texas Department of State Health Services Laboratory Report



South Texas Laboratory
1301 S. Rangerville Road
Harlingen, TX 78552
(956) 364-8746
CLIA: 45D0503753

Submitter: LAGUNA MADRE WATER DISTRICT (TX0310005)
Noe Cantu
105 PORT RD
Port Isabel, TX 78578

LIMS Report #: 2577936

Date / Time Received:	7/24/2019 2:02 pm	Sample Type:	Special
Received By:	LCASTANEDA	Water Source:	N/A
Date Collected:	7/24/2019	County:	Cameron
Time Collected:	10:10 AM	Submitter Designate:	
Collected By:	Pablo Villarreal Jr	Facility ID:	0310005
Sampler Phone Num:	956 572 0382	Smp Collect Pt Name:	
System Type:	Public (PWS)	Turbidity (NTU):	
Sample Temp (°C):	16.8	Disinfect Resid (mg/L):	0.8
Well Depth (ft):		Disinfect Type:	Chloramine (Total Chlorine)
Sample Condition:	ICED	Facility Name:	Laguna Madre
Sample Site:	Corral and Laguna 28	Smp Collect Pt ID:	
Sample #:	SCW1906105 (2664686)	Date Reported:	7/25/2019 10:31 am
Source:	Water		
Billing Comment:	10 - None		
Additional Info:			

Test	Result
Laboratory Chlorine Residual Check	Absent
Colilert Presence - Absence (SM9223)**	Coliforms not found; Escherichia coli not found.
Colilert Test Used	Colilert-18
Date/Time Incubation Started	07/24/2019 02:14:00 PM
Date/Time Incubation Ended	07/25/2019 08:14:00 AM

Note: Water of satisfactory bacteriological quality must be free from coliform organisms. For questions about standards or treatment, call TCEQ at 512-239-4691.

The test results on this report relate only to the sample identified on this report. The test results for analytes noted (*) on this report meet ISO/IEC 17025:2005 requirements. The test results for analytes noted (**) on this report meet TNI (2009 standard) requirements.

Authorized by:

Lab Contact: Deborah Serrato (956) 364-8749

Grace Kubin

Grace Kubin, Ph.D.
Director, Laboratory Services Section

Final



Texas Department of State Health Services Laboratory Report

South Texas Laboratory
1301 S. Rangerville Road
Harlingen, TX 78552
(956) 364-8746
CLIA: 45D0503753

Submitter: LAGUNA MADRE WATER DISTRICT (TX0310005)
Noe Cantu
105 PORT RD
Port Isabel, TX 78578

LIMS Report #: 2577941

Date / Time Received:	7/24/2019 2:02 pm	Sample Type:	Special
Received By:	LCASTANEDA	Water Source:	N/A
Date Collected:	7/24/2019	County:	Cameron
Time Collected:	9:35 AM	Submitter Designate:	
Collected By:	Pablo Villarreal Jr	Facility ID:	0310005
Sampler Phone Num:	956 572 0382	Smp Collect Pt Name:	
System Type:	Public (PWS)	Turbidity (NTU):	
Sample Temp (°C):	16.9	Disinfect Resid (mg/L):	1.0
Well Depth (ft):		Disinfect Type:	Chloramine (Total Chlorine)
Sample Condition:	ICED	Facility Name:	Laguna Madre
Sample Site:	Laguna and Esperanza 23	Smp Collect Pt ID:	
Sample #:	SCW1906110 (2664691)	Date Reported:	7/25/2019 10:32 am
Source:	Water		
Billing Comment:	10 - None		

Additional Info:

Test	Result
Laboratory Chlorine Residual Check	Absent
Colilert Presence - Absence (SM9223)**	Coliforms not found; Escherichia coli not found.
Colilert Test Used	Colilert-18
Date/Time Incubation Started	07/24/2019 02:14:00 PM
Date/Time Incubation Ended	07/25/2019 08:14:00 AM

Note: Water of satisfactory bacteriological quality must be free from coliform organisms. For questions about standards or treatment, call TCEQ at 512-239-4691.

The test results on this report relate only to the sample identified on this report. The test results for analytes noted (*) on this report meet ISO/IEC 17025:2005 requirements. The test results for analytes noted (**) on this report meet TNI (2009 standard) requirements.

Authorized by:

Lab Contact: Deborah Serrato (956) 364-8749

Grace Kubin

Grace Kubin, Ph.D.
Director, Laboratory Services Section

Final

Texas Department of State Health Services Laboratory Report



South Texas Laboratory
1301 S. Rangerville Road
Harlingen, TX 78552
(956) 364-8746
CLIA: 45D0503753

Submitter: LAGUNA MADRE WATER DISTRICT (TX0310005)
Noe Cantu
105 PORT RD
Port Isabel, TX 78578

LIMS Report #: 2577934

Date / Time Received:	7/24/2019 2:02 pm	Sample Type:	Special
Received By:	LCASTANEDA	Water Source:	N/A
Date Collected:	7/24/2019	County:	Cameron
Time Collected:	9:25 AM	Submitter Designate:	
Collected By:	Pablo Villarreal Jr	Facility ID:	0310005
Sampler Phone Num:	956 572 0382	Smp Collect Pt Name:	
System Type:	Public (PWS)	Turbidity (NTU):	
Sample Temp (°C):	16.8	Disinfect Resid (mg/L):	1.1
Well Depth (ft):		Disinfect Type:	Chloramine (Total Chlorine)
Sample Condition:	ICED	Facility Name:	Laguna Madre
Sample Site:	110 E Carolyn 18	Smp Collect Pt ID:	
Sample #:	SCW1906103 (2664684)	Date Reported:	7/25/2019 10:31 am
Source:	Water		
Billing Comment:	10 - None		

Additional Info:

Test	Result
Laboratory Chlorine Residual Check	Absent
Colilert Presence - Absence (SM9223)**	Coliforms not found; Escherichia coli not found.
Colilert Test Used	Colilert-18
Date/Time Incubation Started	07/24/2019 02:14:00 PM
Date/Time Incubation Ended	07/25/2019 08:14:00 AM

Note: Water of satisfactory bacteriological quality must be free from coliform organisms. For questions about standards or treatment, call TCEQ at 512-239-4691.

The test results on this report relate only to the sample identified on this report. The test results for analytes noted (*) on this report meet ISO/IEC 17025:2005 requirements. The test results for analytes noted (**) on this report meet TNI (2009 standard) requirements.

Authorized by:

Lab Contact: Deborah Serrato (956) 364-8749

Grace Kubin, Ph.D.
Director, Laboratory Services Section

Final

Texas Department of State Health Services Laboratory Report



South Texas Laboratory
1301 S. Rangerville Road
Harlingen, TX 78552
(956) 364-8746
CLIA: 45D0503753

Submitter: LAGUNA MADRE WATER DISTRICT (TX0310005)
Noe Cantu
105 PORT RD
Port Isabel, TX 78578

LIMS Report #: 2577940

Date / Time Received:	7/24/2019 2:02 pm	Sample Type:	Special
Received By:	LCASTANEDA	Water Source:	N/A
Date Collected:	7/24/2019	County:	Cameron
Time Collected:	11:10 AM	Submitter Designate:	
Collected By:	Pablo Villarreal Jr	Facility ID:	0310005
Sampler Phone Num:	956 572 0382	Smp Collect Pt Name:	
System Type:	Public (PWS)	Turbidity (NTU):	
Sample Temp (°C):	18.1	Disinfect Resid (mg/L):	0.9
Well Depth (ft):		Disinfect Type:	Chloramine (Total Chlorine)
Sample Condition:	ICED	Facility Name:	Laguna Madre
Sample Site:	Coast Guard Station 3	Smp Collect Pt ID:	
Sample #:	SCW1906109 (2664690)	Date Reported:	7/25/2019 10:32 am
Source:	Water		
Billing Comment:	10 - None		


Additional Info:

Test	Result
Laboratory Chlorine Residual Check	Absent
Colilert Presence - Absence (SM9223)**	Coliforms not found; Escherichia coli not found.
Colilert Test Used	Colilert-18
Date/Time Incubation Started	07/24/2019 02:14:00 PM
Date/Time Incubation Ended	07/25/2019 08:14:00 AM

Note: Water of satisfactory bacteriological quality must be free from coliform organisms. For questions about standards or treatment, call TCEQ at 512-239-4691.

The test results on this report relate only to the sample identified on this report. The test results for analytes noted (*) on this report meet ISO/IEC 17025:2005 requirements. The test results for analytes noted (**) on this report meet TNI (2009 standard) requirements.

Authorized by: _____ Lab Contact: Deborah Serrato (956) 364-8749


Grace Kubin, Ph.D.
Director, Laboratory Services Section

Final

Texas Department of State Health Services Laboratory Report



South Texas Laboratory
1301 S. Rangerville Road
Harlingen, TX 78552
(956) 364-8746
CLIA: 45D0503753

Submitter: LAGUNA MADRE WATER DISTRICT (TX0310005)
Noe Cantu
105 PORT RD
Port Isabel, TX 78578

LIMS Report #: 2577938

Date / Time Received:	7/24/2019 2:02 pm	Sample Type:	Special
Received By:	LCASTANEDA	Water Source:	N/A
Date Collected:	7/24/2019	County:	Cameron
Time Collected:	10:45 AM	Submitter Designate:	
Collected By:	Pablo Villarreal Jr	Facility ID:	0310005
Sampler Phone Num:	956 572 0382	Smp Collect Pt Name:	
System Type:	Public (PWS)	Turbidity (NTU):	
Sample Temp (°C):	16.9	Disinfect Resid (mg/L):	2.2
Well Depth (ft):		Disinfect Type:	Chloramine (Total Chlorine)
Sample Condition:	ICED	Facility Name:	Laguna Madre
Sample Site:	3100 Padre Blvd 8	Smp Collect Pt ID:	
Sample #:	SCW1906107 (2664688)	Date Reported:	7/25/2019 10:31 am
Source:	Water		
Billing Comment:	10 - None		

Additional Info:

Test	Result
Laboratory Chlorine Residual Check	Absent
Colilert Presence - Absence (SM9223)**	Coliforms not found; Escherichia coli not found.
Colilert Test Used	Colilert-18
Date/Time Incubation Started	07/24/2019 02:14:00 PM
Date/Time Incubation Ended	07/25/2019 08:14:00 AM

Note: Water of satisfactory bacteriological quality must be free from coliform organisms. For questions about standards or treatment, call TCEQ at 512-239-4691.

The test results on this report relate only to the sample identified on this report. The test results for analytes noted (*) on this report meet ISO/IEC 17025:2005 requirements. The test results for analytes noted (**) on this report meet TNI (2009 standard) requirements.

Authorized by: _____ Lab Contact: Deborah Serrato (956) 364-8749

Grace Kubin

Grace Kubin, Ph.D.
Director, Laboratory Services Section

Final



Texas Department of State Health Services Laboratory Report

South Texas Laboratory
1301 S. Rangerville Road
Harlingen, TX 78552
(956) 364-8746
CLIA: 45D0503753

Submitter: LAGUNA MADRE WATER DISTRICT (TX0310005)
Noe Cantu
105 PORT RD
Port Isabel, TX 78578

LIMS Report #: 2577939


Date / Time Received:	7/24/2019 2:02 pm	Sample Type:	Special
Received By:	LCASTANEDA	Water Source:	N/A
Date Collected:	7/24/2019	County:	Cameron
Time Collected:	11:00 AM	Submitter Designate:	
Collected By:	Pablo Villarreal Jr	Facility ID:	0310005
Sampler Phone Num:	956 572 0382	Smp Collect Pt Name:	
System Type:	Public (PWS)	Turbidity (NTU):	
Sample Temp (°C):	16.9	Disinfect Resid (mg/L):	2.2
Well Depth (ft):		Disinfect Type:	Chloramine (Total Chlorine)
Sample Condition:	ICED	Facility Name:	Laguna Madre
Sample Site:	550 Padre Blvd 13	Smp Collect Pt ID:	
Sample #:	SCW1906108 (2664689)	Date Reported:	7/25/2019 10:31 am
Source:	Water		
Billing Comment:	10 - None		
Additional Info:			

Test	Result
Laboratory Chlorine Residual Check	Absent
Colilert Presence - Absence (SM9223)**	Coliforms not found; Escherichia coli not found.
Colilert Test Used	Colilert-18
Date/Time Incubation Started	07/24/2019 02:14:00 PM
Date/Time Incubation Ended	07/25/2019 08:14:00 AM

Note: Water of satisfactory bacteriological quality must be free from coliform organisms. For questions about standards or treatment, call TCEQ at 512-239-4691.

The test results on this report relate only to the sample identified on this report. The test results for analytes noted (*) on this report meet ISO/IEC 17025:2005 requirements. The test results for analytes noted (**) on this report meet TNI (2009 standard) requirements.

Authorized by: _____ Lab Contact: Deborah Serrato (956) 364-8749


Grace Kubin, Ph.D.
Director, Laboratory Services Section

Final